


Control of legionella bacteria in water systems

Audit checklists



This is a free-to-download, web-friendly version of *Control of legionella bacteria in water systems: Audit checklists* (published 2003). This version has been adapted for online use from HSE's current printed version.

You can buy packs at <http://books.hse.co.uk>.

ISBN 978 0 7176 2206 1

These checklists are for the health and safety responsible person to use, to audit arrangements in premises, to control legionella in water systems. They audit the risk assessment process and take the responsible person through the recommended measures in the Approved Code of Practice and guidance. There are three checklists:

Checklist 1: The risk assessment, starting on page 3

Checklist 2: Cooling towers, starting on page 5

Checklist 3: Hot and cold water services, starting on page 11

© Crown copyright 2003

First published 2003

ISBN 978 0 7176 2206 1

You may reuse this information (excluding logos) free of charge in any format or medium, under the terms of the Open Government Licence. To view the licence visit www.nationalarchives.gov.uk/doc/open-government-licence/, write to the Information Policy Team, The National Archives, Kew, London TW9 4DU, or email psi@nationalarchives.gsi.gov.uk.

Some images and illustrations may not be owned by the Crown so cannot be reproduced without permission of the copyright owner. Enquiries should be sent to copyright@hse.gsi.gov.uk.

This guidance is issued by the Health and Safety Executive. Following the guidance is not compulsory, unless specifically stated, and you are free to take other action. But if you do follow the guidance you will normally be doing enough to comply with the law. Health and safety inspectors seek to secure compliance with the law and may refer to this guidance.

Introduction

These checklists are designed to help you, as the **responsible person**, audit the arrangements in place to control legionella in the water systems in your premises. This is a check on your knowledge of the system. It also checks the knowledge of those who play a role in controlling the risks from the system, for example water treatment contractors. There would be no value in asking a third party to complete this audit. As the responsible person, you should have been appointed because you have 'sufficient authority, competence and knowledge' of the systems in your workplace.¹

The checklists are not risk assessments. They have been prepared on the basis that you have already identified a risk system(s) in your workplace and that you need to put in place (or review) measures to prevent or control the risks from exposure to legionella bacteria. However, the first checklist addresses a number of issues relating to the risk assessment, so you can audit the assessment process itself.

The system checklists (Checklist 2 covers cooling towers; Checklist 3 covers hot and cold water services) take you through the recommended

measures in the Approved Code of Practice (ACOP) and guidance¹ on controlling legionella bacteria in water systems. These allow you to audit the arrangements you have in place or intend to put in place. A negative answer to any of the questions indicates that you need to review the arrangements you have in place.

The checklists do not give guidance on how to achieve control, you should consult the ACOP and guidance¹ for detail on control measures and how they are put in place and monitored.

Using the system checklists requires you to carry out both a physical inspection of the system as well as examining the management procedures and paperwork in place. You also need to talk to those who may have responsibilities for any aspects of the control regime.

The checklists only cover the two main risk systems. You will also need to assess whether there are other sources of risk in your workplace and put in place appropriate control measures.

Name of auditor

Date of audit

Date of review (see Checklist 1: Note 2)

Action required (list)

--	--

Completed

--

Checklist 1

The risk assessment

	YES	NO
<p>1 Did you consider whether you could eliminate the risk?</p> <p><i>Note 1: Your primary duty under the Control of Substances Hazardous to Health Regulations is to prevent the risks from exposure. You may be able to do this by looking at the type of water system you need, for example you may not need a wet cooling system.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>2 Did the person carrying out the assessment have access to competent help and advice when carrying out the assessment?</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>3 If there are more than five employees in your organisation, did you record the significant findings of the assessment?</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>4 Did you consult employees about the assessment and the control measures?</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5 Have you identified the circumstances which would require a review of the assessment?</p> <p><i>Note 2: Your assessment should be reviewed regularly – at least every two years, and whenever it is suspected it is no longer valid, for example if there is a significant change to the system.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>

Managing the risks: Roles and responsibilities

<p>6 Has a 'responsible person' been identified in writing?</p> <p><i>Note 3: If risks have been identified, there needs to be someone to take charge of managing the control regime.</i></p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>7 Is there a nominated deputy?</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>8 Are contact details for these people readily available (in the event of an emergency)?</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>9 Are the roles and responsibilities of all the staff involved in the control regime clearly defined in writing?</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>10 Have they all received appropriate training?</p>	<input type="checkbox"/>	<input type="checkbox"/>

		YES	NO
11	If external contractors are used, are their roles and responsibilities clearly defined in writing? <i>Note 4: The demarcation between contractor and occupier needs to be defined, ie who does what. But remember that using contractors does not absolve you of the responsibility for ensuring that the control regime is carried out.</i>	<input type="checkbox"/>	<input type="checkbox"/>
12	Have you checked the competence of contractors? <i>Note 5: For example, you should ask about experience and qualifications, how their staff are trained, and whether they are a member of a professional organisation/recognised trade body, for example the Code of Conduct Association. You can find out about the health and safety performance of companies by checking HSE's enforcement databases (www.hse.gov.uk/notices and www.hse.gov.uk/prosecutions).</i>	<input type="checkbox"/>	<input type="checkbox"/>
13	Have you considered all other health and safety issues (eg COSHH assessments for handling of water treatment chemicals, working at height, working in confined spaces, electrical safety and ease of access to parts of the system)?	<input type="checkbox"/>	<input type="checkbox"/>

Checklist 2

Cooling towers

YES

NO

Record details of tower below (ie make, model, year of manufacture, type) - you should complete a checklist for each tower.

--

- 1** Has the cooling tower(s) been notified to your local authority?

Note 1: Under the Notification of Cooling Towers and Evaporative Condensers Regulations, you must notify the local authority in writing with details of where it is based. If it is taken out of use, you also need to tell them.

Managing the risks: The written scheme

- 2** Is there a written scheme for controlling the risk from exposure to legionella bacteria?

Note 2: If your assessment has shown that there is a reasonably foreseeable risk of exposure to legionella bacteria, there needs to be a written scheme in place to control that risk.

- 3** Does the scheme contain an up-to-date plan of the system (a schematic plan is OK)?

- 4** Does the plan show:

■ all cooling towers?

■ all system control valves?

■ all standby equipment, eg spare pumps?

■ the location of system bleed valves?

■ all associated storage tanks?

■ all associated pipework?

■ the location of chemical dosing points and/or injection points?

■ the location of the system drain valve?

		YES	NO
	<ul style="list-style-type: none"> the origin of the water supply? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> any parts that may be temporarily out of use? 	<input type="checkbox"/>	<input type="checkbox"/>
5	Does the scheme contain instructions for operating the system (see Q17-21)?	<input type="checkbox"/>	<input type="checkbox"/>
6	Does the scheme contain details of the precautions to be taken to control the risk of exposure to legionella bacteria (see Q22-26)?	<input type="checkbox"/>	<input type="checkbox"/>
7	Does the scheme contain details of the checks that are to be carried out (and their frequency) to ensure that the scheme is effective (see Q27-38)?	<input type="checkbox"/>	<input type="checkbox"/>

■ Cooling systems: Design and construction

8	If you are installing a new tower, have you considered its position in relation to:		
	<ul style="list-style-type: none"> air conditioning and ventilation inlets? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> opening windows? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> occupied areas (for example consider the population density and the proximity of those who may be more vulnerable to infection, for example in hospitals)? 	<input type="checkbox"/>	<input type="checkbox"/>

Note 3: Remember that you have duty to protect those who may be affected by the risks created by your towers.

9	Is the tower constructed from impervious materials?	<input type="checkbox"/>	<input type="checkbox"/>
---	---	--------------------------	--------------------------

Note 4: Preserved timber can be used but it must be impervious and easy to clean and disinfect.

10	Are drift eliminators fitted?	<input type="checkbox"/>	<input type="checkbox"/>
11	Are they:		
	<ul style="list-style-type: none"> fitted correctly? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> effective? 	<input type="checkbox"/>	<input type="checkbox"/>

Note 5: Drift eliminators do not eliminate drift but they do reduce it. You should use those which control the release of small water droplets. For example, wooden slats don't do this and must be replaced.

		YES	NO
12	Is the area above the pond as enclosed as possible?	<input type="checkbox"/>	<input type="checkbox"/>
13	Are all visible surfaces free from:		
	■ slime or algae?	<input type="checkbox"/>	<input type="checkbox"/>
	■ scale?	<input type="checkbox"/>	<input type="checkbox"/>
	■ corrosion?	<input type="checkbox"/>	<input type="checkbox"/>
14	Does the water flow evenly across the fill pack?	<input type="checkbox"/>	<input type="checkbox"/>
15	Have all the following been removed as far as possible:		
	■ dead legs/blind ends?	<input type="checkbox"/>	<input type="checkbox"/>
	■ redundant pipework?	<input type="checkbox"/>	<input type="checkbox"/>
	■ redundant plant?	<input type="checkbox"/>	<input type="checkbox"/>
16	Are those parts of the tower that become wet, accessible and/or removable for cleaning?	<input type="checkbox"/>	<input type="checkbox"/>

■ Operation and maintenance

17	Is the system in regular operation (if no, see Q20-21)?	<input type="checkbox"/>	<input type="checkbox"/>
18	Are there procedures in place to operate standby equipment on a rotational basis?	<input type="checkbox"/>	<input type="checkbox"/>
19	Is there an operations manual for the cooling system?	<input type="checkbox"/>	<input type="checkbox"/>

Non-regular use

20	If the tower is used intermittently or is required at short notice, is it run at least once a week, so that water treatment chemicals are circulated to all parts of the system?	<input type="checkbox"/>	<input type="checkbox"/>
21	If the tower is out of use for longer than a week, are there procedures in place to bring the tower back into operation safely?	<input type="checkbox"/>	<input type="checkbox"/>

YES

NO

Water treatment programme

22 Is there a water treatment programme in place?

23 Are chemicals/biocides used to control:

■ scale?

■ corrosion?

■ fouling?

■ microbiological activity?

If no to any of the above, list methods used below.

24 If non-oxidising biocides are used, are two used alternately?

25 Are chemicals dosed automatically?

26 If yes to Q25, are the pumps calibrated regularly?

Note 5: Although there is no requirement for automatic dosing, you should consider issues associated with manual dosing - the health and safety risks, for example manual handling and exposure to chemicals, to staff who carry out manual dosing, as well as the management of the process to make sure the frequency and rate of application are maintained.

YES

NO

Monitoring

27 Is there a daily check to make sure that the system is operating as described in the operations manual?

28 Is there a daily visual check of the cleanliness of the water in the system?

29 Is the physical condition of the system checked at least every week?

30 Is the chemical composition of the cooling and make-up water monitored on a regular basis?

Note 6: A number of different parameters are given in Table 1 of the ACOP and guidance.¹ You should be clear what parameters you need to measure and what they are telling you about the operation of your tower. Usual parameters that are monitored include hardness (calcium, magnesium and total hardness), conductivity and the concentration factor.

31 Are the safe operating limits for each parameter which is being measured, known and recorded in the operating manual?

32 Is the corrective action for out of limit situations known and included in the operations manual?

33 Are results of all tests and checks recorded, together with details of any remedial action taken (if required)?

34 Are dip slides taken on at least a weekly basis?

35 Are slides incubated in an incubator (at 30°C for 48 hours)?

36 Are results recorded, so trends over time can be seen?

37 Are samples for legionella taken on at least a quarterly basis?

38 Have the circumstances when more frequent sampling may be required been identified and recorded?

		YES	NO
<i>Cleaning and disinfection</i>			
39	Is there a written procedure for regular cleaning and disinfection of the system?	<input type="checkbox"/>	<input type="checkbox"/>
40	Does this take place at least every six months (if not, see Q43)?	<input type="checkbox"/>	<input type="checkbox"/>
41	Does the cleaning and disinfection procedure include:		
	■ initial concentration of oxidising biocide in use for the pre- and post-cleaning disinfection stages?	<input type="checkbox"/>	<input type="checkbox"/>
	■ contact time for each disinfection stage?	<input type="checkbox"/>	<input type="checkbox"/>
	■ methods for carrying out cleaning, including the removal of packing?	<input type="checkbox"/>	<input type="checkbox"/>
42	If packs cannot be removed, are there alternative methods of making sure they remain clean in place (list methods below)?	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="text"/>		
43	If the system is not shut down every six months, list reasons and alternative measures taken to ensure the cleanliness of the system below.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="text"/>		
44	Are measures taken to protect staff when carrying out cleaning of the tower - list precautions below?	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="text"/>		

Checklist 3

Hot and cold water services

	YES	NO
Type of system(s) (tick)		
<input type="checkbox"/> Gravity without recirculation		
<input type="checkbox"/> Gravity with recirculation		
<input type="checkbox"/> Pressurised		
<input type="checkbox"/> Other (describe below)		

Managing the risks: The written scheme

1	Is there a written scheme for controlling the risk from exposure to legionella bacteria?	<input type="checkbox"/>	<input type="checkbox"/>
	<i>Note 1: If your assessment has shown that there is a reasonably foreseeable risk of exposure to legionella bacteria, there needs to be a written scheme in place to control that risk.</i>		
2	Does the scheme contain an up-to-date plan of the system (a schematic is OK)?	<input type="checkbox"/>	<input type="checkbox"/>
3	Does the plan show and identify:		
	<ul style="list-style-type: none"> ■ all system plant, for example water softeners, filters, strainers, pumps, non-return valves and all outlets, for example showers, wash-hand basins etc? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> ■ all standby equipment, for example spare pumps? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> ■ all associated pipework and piping routes? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> ■ all associated storage and header tanks? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> ■ the origin of water supply (see Q18)? 	<input type="checkbox"/>	<input type="checkbox"/>
	<ul style="list-style-type: none"> ■ any parts that may be out of use temporarily? 	<input type="checkbox"/>	<input type="checkbox"/>
4	Does the scheme contain instructions for the operation of the system (see Q18-23)?	<input type="checkbox"/>	<input type="checkbox"/>

	YES	NO
5 Does the scheme contain details of the precautions to be taken to control the risk of exposure to legionella bacteria (see Q24-26)?	<input type="checkbox"/>	<input type="checkbox"/>
6 Does the scheme contain details of the checks that are to be carried out (and their frequency) to ensure that the scheme is effective (see Q27-40)?	<input type="checkbox"/>	<input type="checkbox"/>

Design and construction

7 If you are fitting a new system, do any of the materials or fittings used in the water systems support the growth of micro-organisms? <i>Note 2: The Water Research Centre publish a directory which lists materials and fittings acceptable for use in water systems.</i>	<input type="checkbox"/>	<input type="checkbox"/>
8 Are low corrosion materials used?	<input type="checkbox"/>	<input type="checkbox"/>
9 If fitted, are thermostatic mixing valves (TMVs) sited as close as possible to the point of use? <i>Note 3: Ideally, TMVs should not be fitted to multiple outlets but, if they are used, the mixed water pipework should be kept as short as possible.</i>	<input type="checkbox"/>	<input type="checkbox"/>

Cold water system

10 Are low use outlets installed upstream of higher use outlets?	<input type="checkbox"/>	<input type="checkbox"/>
11 Has cold water storage been assessed and minimised, ie holds enough for a day's use only?	<input type="checkbox"/>	<input type="checkbox"/>
12 Is piping insulated and kept away from heat sources (where possible)?	<input type="checkbox"/>	<input type="checkbox"/>
13 Is the cold water tank:		
■ fitted with a cover and insect screen(s) on any pipework open to the atmosphere?	<input type="checkbox"/>	<input type="checkbox"/>
■ located in a cool place and protected from extremes of temperature?	<input type="checkbox"/>	<input type="checkbox"/>
■ accessible?	<input type="checkbox"/>	<input type="checkbox"/>

		YES	NO
Hot water system			
14	Does the calorifier storage capacity meet normal daily fluctuations in hot water use while maintaining a supply temperature of at least 50°C (see Note 5)?	<input type="checkbox"/>	<input type="checkbox"/>
15	Are the hot water distribution pipes insulated?	<input type="checkbox"/>	<input type="checkbox"/>
16	If more than one calorifier is used, are they connected in parallel?	<input type="checkbox"/>	<input type="checkbox"/>
17	Does the calorifier have the following fitted:		
	■ a drain valve?	<input type="checkbox"/>	<input type="checkbox"/>
	■ a temperature gauge on the inlet and outlet?	<input type="checkbox"/>	<input type="checkbox"/>
	■ an access panel?	<input type="checkbox"/>	<input type="checkbox"/>

■ Operation and maintenance

18	If the water supplied to your building is not mains supply, has the water been pre-treated to make sure it is of the same quality as the mains?	<input type="checkbox"/>	<input type="checkbox"/>
19	Is the entire contents of the calorifier, including the base, heated to 60°C for an hour each day, for example by using a shunt pump?	<input type="checkbox"/>	<input type="checkbox"/>
20	Are all outlets that are no longer required cut back as far as the main pipe run?	<input type="checkbox"/>	<input type="checkbox"/>
21	Are there arrangements to incorporate standby equipment, for example calorifiers, pumps, into routine use?	<input type="checkbox"/>	<input type="checkbox"/>
22	If little used outlets have not been removed, are there arrangements in place to either:		
	■ flush them through on at least a weekly basis (with records kept of this)? or	<input type="checkbox"/>	<input type="checkbox"/>
	■ carry out a safe purge of stagnant water before use?	<input type="checkbox"/>	<input type="checkbox"/>

Note 4: It is important that this purge is carried out with the minimum production of aerosols, for example by piping directly to the drain.

	YES	NO
23 If thermostatic mixing valves are fitted, are they included in the maintenance schedule?	<input type="checkbox"/>	<input type="checkbox"/>

Water treatment programme

24 Is there a water treatment programme in place?	<input type="checkbox"/>	<input type="checkbox"/>
25 Is temperature used as a control method (go to Q27)?	<input type="checkbox"/>	<input type="checkbox"/>
26 Are biocides used as a control method? Give the method below (go to Q33).	<input type="checkbox"/>	<input type="checkbox"/>
<div style="border: 1px solid black; height: 60px; width: 100%;"></div>		

Monitoring

Temperature

27 If there is a risk of scalding (for example where the young, elderly or disabled may use the outlets), are thermostatic mixing valves fitted?	<input type="checkbox"/>	<input type="checkbox"/>
28 Is the temperature of sentinel hot and cold water outlets checked on a monthly basis?	<input type="checkbox"/>	<input type="checkbox"/>
<i>Note 5: For cold water, the temperature should be 20°C or below and for hot water, at least 50°C.</i>		
29 If fitted, is the temperature of the water supply to thermostatic mixing valves checked on a monthly basis?	<input type="checkbox"/>	<input type="checkbox"/>
30 Is the temperature of the water in the outlet and return pipes of the calorifier checked on a monthly basis?	<input type="checkbox"/>	<input type="checkbox"/>
31 Is the temperature of the incoming cold water supply checked on a six-monthly basis?	<input type="checkbox"/>	<input type="checkbox"/>
32 Is the temperature of a representative number of hot and cold water outlets checked on an annual basis?	<input type="checkbox"/>	<input type="checkbox"/>

		YES	NO
<i>Biocides</i>			
33	Is the control level required known and recorded in the operations manual?	<input type="checkbox"/>	<input type="checkbox"/>
34	Is the rate of release/rate of addition of biocide known and recorded?	<input type="checkbox"/>	<input type="checkbox"/>
35	Is the concentration of the biocide at sentinel outlets checked on a monthly basis?	<input type="checkbox"/>	<input type="checkbox"/>
36	Is the concentration of biocide checked at representative outlets on an annual basis?	<input type="checkbox"/>	<input type="checkbox"/>
<i>General</i>			
37	On an annual basis is there:		
	■ a visual check of the cold water tank and the water in it?	<input type="checkbox"/>	<input type="checkbox"/>
	■ a check to see if there is reasonable flow through the cold water tank, ie good tangential flow across the tank?	<input type="checkbox"/>	<input type="checkbox"/>
	■ a drain of the calorifier and a check for debris?	<input type="checkbox"/>	<input type="checkbox"/>
	■ a check on the plans for the hot and cold water circuits to make sure they are up to date?	<input type="checkbox"/>	<input type="checkbox"/>
	■ a check on the existence of all water connections to outside services?	<input type="checkbox"/>	<input type="checkbox"/>
38	Are results of all tests and checks recorded, together with details of any remedial action taken (if required)?	<input type="checkbox"/>	<input type="checkbox"/>
<i>Microbiological</i>			
39	Are there procedures in place to identify circumstances when either general microbiological monitoring or sampling for legionella would be appropriate?	<input type="checkbox"/>	<input type="checkbox"/>
40	If there are procedures in place, do these identify where samples should be taken, and the frequency and actions required?	<input type="checkbox"/>	<input type="checkbox"/>

YES

NO

Cleaning and disinfection

41	Have the circumstances when cleaning and disinfection of the hot water system would be appropriate been identified?	<input type="checkbox"/>	<input type="checkbox"/>
42	If cleaning and disinfection were to be carried out, which of the following methods would be used?		
■	thermal?	<input type="checkbox"/>	<input type="checkbox"/>
■	chemical?	<input type="checkbox"/>	<input type="checkbox"/>
43	Are procedures in place for the chosen method of cleaning and disinfection?	<input type="checkbox"/>	<input type="checkbox"/>

References

- 1 *Legionnaires' disease. The control of legionella bacteria in water systems. Approved Code of Practice and guidance L8 (Second edition)*
HSE Books 2000 ISBN 978 0 7176 1772 2.

Further information

For information about health and safety, or to report inconsistencies or inaccuracies in this guidance, visit www.hse.gov.uk/. You can view HSE guidance online and order priced publications from the website. HSE priced publications are also available from bookshops.

This document is available at www.hse.gov.uk/pubns/books/ck02.htm